

# *The small PMT : operation and performances*

*Antonella Castellina  
INFN and INAF - Torino*



Contributions from  
INFN-Catania  
INFN-Napoli  
INFN-Torino  
IPN-Orsay  
Malargüe staff


# Small PMT unit

1510 units to be installed (excluding the external border of 150 stations)

- 1477 already installed
- 33 missing (25 in forbidden areas, 8 due to problematic installation)




**1 unit =**

- ▶ sPMT R8619
- ▶ HVPS A7501
- ▶ mechanics
- ▶ cables




# sPMT - production

- All specifications for production collected in [EDMS PAO-000273-ProductionsPlan](#)
- Datasheets, descriptions and tools collected in [EDMS PAO-000274-ProductionDocuments](#)



# 1- Tests before shipping - by providers

- All parts of the SPMT units have been tested
- Documentation in *EDMS PAO-000275-TestAssemblyProcedures*
- Results in *EDMS PAO-000276* and *PAO-000267—TestReports and Link to test results*



## Dividers

- tested by NeOhm Co. before delivering to Hamamatsu
- some gold plated soldering points discolored : defective bases discarded by Hamamatsu, NeOhm agreed to replace them
- reason: thickness of deposition under specs

## SPMT with flying leads

- tested by Hamamatsu (requirements checked)

## HVPS

- tested by CAEN



Costruzioni Apparecchiature Elettroniche Nucleari C.A.E.N. S.p.A.  
Via Vetraria, 11 - 55049 Viareggio (LU) - Italy  
+39.0584.388.398 - fax +39.0584.388.959  
info@caen.it - www.caen.it

Viareggio, March 30<sup>th</sup> 2018  
Ricci Giacomo

## A7501PB – s/n 159

Required converter specification	Range & accuracy	
Main voltage supply	$V_{cc} = 12V \pm 5\%$	✓
Temperature range	$-20^{\circ}C < T < 60^{\circ}C$	✓
Output voltage $V_{out}$	$V_{min} = 0V < V_{out} < V_{max} = 2100V$	✓
Input command $V_{cin}$	$0 < V_{cin} < 2.5V$ ( $V_{cin} = 2.5V$ at $V_{max}$ )	✓
Output voltage monitor $V_{mon}$	$0 < V_{mon} < 5V$ ( $V_{mon} = 5V$ at $V_{max}$ )	✓
Power absorption	$P_{abs} < 500$ mW at $V_{max}$	✓
Uniformity of output voltage $V_{out}$ for a constant $V_{cin}$ command	$< 10^{-3}$	✓
$\Delta V_{out}/V_{out}$ fluctuation vs $V_{cc}$	$\Delta V_{out}/V_{out} < 1\%$ at $V_{out} > 500V$	✓
Integral non linearity for $V_{out}$ vs $V_{cin}$	$< 2 \cdot 10^{-3}$ at $V_{out} > 500V$	✓
Integral non linearity for $V_{mon}$ vs $V_{out}$	$< 2 \cdot 10^{-3}$ at $V_{out} > 500V$	✓
Termal stability $\Delta V_{out}/V_{out}$ , T	$< 10^{-4}^{\circ}C^{-1}$	✓

Vset (V)	Vout (V)	Vmon (V)	Imon (V)	Iin (mA)	PWR in (mW)	Vout/Vset INL	Vout/Vmon INL	Vout/Vmon INL	Imon/Vset INL	Imon/Vset INL
0,0011	14,4174	0,0256	0,0088	4,5361	56,0845	12826,8786	54,28%	562,6702	-8,14%	7,8158
0,0980	86,1153	0,1959	0,0570	7,4485	92,0941	878,2884	-2,26%	439,6410	-1,23%	0,5818
0,2017	174,4525	0,4054	0,1166	8,6631	107,1110	865,1081	-0,39%	430,3298	-0,47%	0,5781
0,3034	260,1415	0,6087	0,1743	9,6186	118,9258	857,4322	-0,20%	427,4017	-0,23%	0,5745
0,4037	344,7160	0,8095	0,2313	10,4990	129,8108	853,8597	-0,07%	425,8555	-0,13%	0,5729
0,5008	426,5719	1,0037	0,2865	11,3259	140,0342	851,7964	0,00%	425,0046	-0,06%	0,5721
0,6008	510,6580	1,2033	0,3431	12,1854	150,6619	850,0144	0,01%	424,3774	-0,02%	0,5712
0,7044	597,9467	1,4103	0,4020	13,1063	162,0482	848,8811	0,04%	423,9839	0,02%	0,5706
0,8026	680,5937	1,6066	0,4577	13,9784	172,8304	847,9418	0,05%	423,6166	0,03%	0,5702
0,9004	762,8796	1,8020	0,5132	14,8608	183,7412	847,2995	0,06%	423,3631	0,05%	0,5699
0,9967	843,6253	1,9938	0,5676	15,7408	194,6211	846,4304	0,03%	423,1190	0,05%	0,5695
1,1039	934,0836	2,2087	0,6287	16,7468	207,0589	846,1454	0,06%	422,9037	0,06%	0,5695
1,2037	1017,2762	2,4075	0,6851	17,6903	218,7254	845,1461	-0,01%	422,5429	0,02%	0,5692
1,2960	1093,9935	2,5915	0,7374	18,5764	229,6805	844,1621	-0,08%	422,1473	-0,04%	0,5690
1,4007	1182,0961	2,8012	0,7970	19,6010	242,3491	843,9222	-0,07%	421,9978	-0,05%	0,5690
1,5041	1269,3130	3,0083	0,8558	20,6230	254,9846	843,9121	-0,04%	421,9399	-0,03%	0,5690
1,5985	1348,9342	3,1974	0,9095	21,5661	266,6461	843,8549	-0,02%	421,8890	-0,02%	0,5689
1,7005	1434,6796	3,4011	0,9673	22,5933	279,3461	843,6637	-0,02%	421,8265	-0,02%	0,5688
1,8007	1519,0240	3,6016	1,0242	23,6157	291,9877	843,5578	-0,01%	421,7680	-0,01%	0,5688
1,9049	1606,4866	3,8093	1,0832	24,6864	305,2255	843,3651	-0,01%	421,7305	0,00%	0,5686
2,0023	1688,5989	4,0044	1,1386	25,7006	317,7649	843,3313	0,00%	421,6861	0,00%	0,5686
2,1049	1774,7725	4,2093	1,1966	26,7732	331,0272	843,1796	0,00%	421,6362	0,00%	0,5685
2,2042	1858,3829	4,4081	1,2528	27,8214	343,9875	843,1134	0,01%	421,5869	0,00%	0,5684
2,3005	1939,4036	4,6007	1,3069	28,8512	356,7198	843,0262	0,01%	421,5484	0,01%	0,5681
2,3962	2019,8343	4,7919	1,3613	29,8707	369,3250	842,9308	0,01%	421,5077	0,01%	0,5681
2,5017	2108,9869	5,0036	1,4216	31,0193	383,5261	843,0249	0,03%	421,4944	0,01%	0,5683
Interpolation line slope "m"					840,497123	420,476459		0,56728114		
Interpolation line intercept "q"					5,64754198	4,81687131		0,00240774		

\* step out of relevant range (Vout<400V). This step has been discarded for statistics.



# 1- Tests before shipping - at INFN labs

## PMT test (INFN-Napoli)

- 16 sPMT tested in one shot
- Double dynamics front-end: x12 amplifier for SPE/MIP measurements, /7 attenuator for linearity
- results in MySQL database and ascii



[M.Buscemi et al., JINST 15 (2020) 07, P07011]



## HVPS test (INFN-Torino & Catania)

- two identical test systems
- tests at room temperature and in climatic chamber
- results in <https://pandora.infn.it/public/b4022a>




[G.Anastasi et al., JINST 17 (2022) T04003]

EDMS PAO-000275-Test and assembly procedures

# 1- Tests before shipping - at INFN labs


## PMT test (INFN-Napoli)

- Only 2 out of 1290 discarded



## HVPS test (INFN-Torino & Catania)

- ~150 HVPS rejected and replaced (bad soldering for one pin+one bad component identified)
- All modules in agreement with specifications



# More tests: sPMT dependence on Temperature

[GAP2016-078]

## Components sensitive to temperature


→ High Voltage Power Supply

$$\frac{|\Delta HV_{out}|}{HV_{out} \Delta T} = 2.5 \cdot 10^{-5} / {}^\circ C$$

→ PCB + Divider

$$\left( \frac{\Delta G}{G \Delta T} \right) < 3\%$$

→ Photomultipliers [contributions from dynode multipliers and Photocathode Quantum Efficiency]




## 2- Test before deployment - at SDEco


### EDMS PAO-000275-Test and assembly procedures

Light source (Scionix  $^{241}\text{Am}$ -YAP:Ce),  $\sim 22$  Bq, providing pulses of constant intensity at  $\sim 15$  Hz.

- fast and simple checks by oscilloscope at the required SPMT gain:  $\langle P \rangle$  and  $\langle Q \rangle$  averaged over 512 pulses
- result largely independent of acquisition threshold: robust technique to monitor the gain at % accuracy in few mins



- database with results available at SDECo



THRs [mV]	$\langle \text{Peak} \rangle_{512}$ [mV]	$\langle Q \rangle_{512}$ [nV/s]
20	284	10.6
40	291	10.9
60	292	10.9
80	294	10.9
100	293	11.0
120	293	11.0
140	295	11.0


# sPMT - problems from the field

Only 16 SPMTs since their deployment experienced problems affecting their performances.

*EDMS PAO-000276-SPMT Problems at test and field*


## ● Water/humidity damage to the divider components

- cause: incomplete sealing due to missing silicone application at production (Zener)
- All SPMT deployed after November 2022 properly sealed by the local staff



## ● Unstable I<sub>mon</sub>

- cause: probably originated by humidity
- almost always solved by changing the base



## ● Transmission problems in monitoring data

- cause: still unknown, under study

# sPMT - problems from the field

---

Only 16 SPMTs out of 1547 installed units experienced problems affecting their performances.  
In 12 out of 16 cases, the SPMT was installed prior to November 2022 —> no correct sealing

No failures found on SPMT tube or HVPS up to now (~1 year)

Malfunctioning in the field difficult to solve: either sporadic or due to environmental causes that disappear in lab

However, checking contacts and/or replacing the divider solves most problems

Note that

- the dividers have only passive components
- low cost ~15€/unit
- a large batch of spares is available (>370)



No need for a dedicated test system in SDEco

# sPMT - spare parts


## ● photomultipliers+base+cables+mechanics

- 1477 installed, 33 still missing
- **148 spare units**



## ● Dividers

- 66 remaining from the production
- other two batches of 150+160 bases have been produced
- **376 spare units**



## ● HV modules

- **185 spare units**



## ● Control cables (HV to UUB)

- **129 spare units**

## ● Clamps

- **400**

*EDMS PAO-000276-SPMT Spare parts*

# Documentation

- **Productions Plans** PAO-000273
  - 📄 2491602 (v.1) Agreement between the Pierre Auger Collaboration and Hamamatsu for the furniture of up to 1700 photomultiplier
  - 📄 2491603 (v.1) Hamamatsu PHOTOMULTIPLIER TUBE R8619 Data Sheet
  - 📄 2491604 (v.1) Hamamatsu and INFN Torino activity for Pierre Auger upgrade
  - 📄 2491605 (v.1) Requirements for 1700 High Voltage Power Supply modules for the Pierre Auger Observatory
  - 📄 2491606 (v.1) Technical Requirements for the supply of up to 1700 photomultipliers model R8619SEL-10 MOD3
  - 📄 2491607 (v.1) SPMT Bases production Plan
  - 📄 2491608 (v.1) Specifiche per la fornitura di 1700 schede partitore di tensione per il fotomoltiplicatore Hamamatsu R8619
- **Productions Documents** PAO-000274
  - 📄 2491845 (v.1) SPMT Production Documents
  - 📄 2491846 (v.1) SPMT Bases Production documents
  - 📄 2491847 (v.1) SPMT HVPS Production documents
  - 📄 2491848 (v.1) SPMT Mechanics Production documents

Technical docs

Procedures

Test results

Maintenance

- **Tests\_&\_Assembly\_Procedures** PAO-000275
  - 📄 2491612 (v.1) A facility to validate photomultipliers for the upgrade of the Pierre Auger Observatory
  - 📄 2491613 (v.1) Hamamatsu R8619 Base Measurements
  - 📄 2491614 (v.1) SPMT Bases Tests Procedures
  - 📄 2491841 (v.1) Specifiche per la procedura di assemblaggio di 800 fotomoltiplicatori Hamamatsu R8619SEL-10 MOD3.
  - 📄 2491843 (v.1) Test bench and validation for the CAEN A7501PB HV-boxes of AugerPrime
  - 📄 3071162 (v.1) Validation of high voltage power supplies for the small PMT
  - 📄 3071263 (v.1) Procedure for the test of SPMT with YAP light source
- **Deployment** PAO-000263
  - 📄 2175217 (v.1) SPMT INSTALLATION PROCEDURE
  - 📄 2804588 (v.2) SPMT Sealing procedure

- **Tests Reports** PAO-000276
  - 📄 2491610 (v.1) Quantum Efficiency for R8619 PMT
  - 📄 2491611 (v.1) CAEN Test report on HVPS A7501PB
- **Link to the Tests Results repository in Italy** PAO-000267
  - 📄 2273463 (v.1) Link to the Tests Results repository

- **Maintenance** PAO-000276
  - 📄 3071612 (v.1) Small PMT Spare Parts
  - 📄 3071614 (v.1) SPMT problems at test and field

The local staff is fully trained to perform all activities related to the SPMT  
Reference person : Juan Pablo Gongora

# sPMT - setting and calibration

[GAP2022-018]



Only ~1 phe/muon, due to small area

Exploit **local small showers** (~200/hour) : T1 events selected requiring a 2-fold coincidence among the LPMTs signals above a threshold  $S_{\text{peak}}(\text{LPMTs})$  changing with the individual LPMTs counting rates.

Small showers are used to:

- Set the HV allowing to measure signals without saturation at least up to 20,000 VEM
- Cross-calibrate the SPMT against calibrated signals from the LPMTs

...and they can provide a continuous monitoring of the LPMTs



# sPMT - HV setting

GOAL : set the HV allowing to measure  $S_{\text{target}} = 22,500 \text{ VEM} (\pm 10\%)$

Saturation determined by the FADC dynamic range

DR = 4095 - baseline ~ 3845 FADC counts

In first approximation


$$Q_{\max} = AoP_{\text{ref}} \times DR$$

Thus, for the SPMT signal

$$S_{\max} = AoP_{\text{ref}} \times DR \times \beta$$

where  $AoP_{\text{ref}}$  is the signal width and  $\beta$  the calibration factor

Procedure performed on-tank using small showers in 12h blocks and comparing  $S_{\max}$  to  $S_{\text{target}}$   
Optimal result reached after 12 hours (one HV change)




- Automatic procedure activated in July 2023
- code maintained in the SDE/UUB/DAQ gitlab repository

# sPMT - Dynamic range


GOAL : set the HV allowing to measure signals  
without saturation at least up to 20,000 VEM

Maximum signal without saturation  $S_{\max}$  estimated using small showers data



→ Procedure succesful in almost all SPMTs (~1% failure)

→ Bad periods are due to loss of small shower files



Small showers stored by CDAS-DAQ in one spmt\_yyyy\_mm\_dd.root file per day  
with data from ~00:00 to ~23:59 of dd/mm/yyyy from the whole array (< 300 MB/day)

Codes in the [SDEU/UUB/daq](#) and [CDAS-DAQ](#) repositories




# sPMT - calibration

Only ~1 phe/muon, due to small area

Cross-calibration against LPMT calibrated signals using local small showers (~200/hour)

$$S_{\text{SPMT}}[\text{VEM}] = \beta \times Q_{\text{SPMT}}[\text{FADC counts}]$$

- Calibration parameter  $\beta$  determined every hour with **~2.2% precision** using data from 8 hour sliding windows
- Daily evolution in  $\beta$  :  $\pm 8\%$  (anode sensitivity from lab measurements  $-0.38\%/\text{^oC}$ , daily excursion  $\sim 20\text{^oC}$ )






Calibration running on CC-IN2P3 ([code in the gitlab repository](#)) producing 1 ROOT file per day for the whole array, stored in /sps/pauger/users/ganastasi/SPMTcalibration\_results/v2r0/

[GAP2022-018]


# Stability of cross-calibration

$\sigma[\beta]/\beta < 5\%$

$\sigma[(S_{SPMT} - S_{LPMTs})/S_{LPMTs}]$   
~ 10-12%



Daily relative dispersion of SPMT signal w.r.t. LPMTs avg.




# Stability of cross-calibration


$\sigma[\beta]/\beta < 6\%$

$\sigma[(S_{SPMT} - S_{LPMTs})/S_{LPMTs}] \sim 13-15\%$


Inter-calibration factor  $\beta$  - Lsld 822




Daily relative dispersion of  $\beta$




Daily relative dispersion of SPMT signal w.r.t. LPMTs avg.



# Evolution with time



# sPMT - monitoring



Monitoring of **SPMT inter-calibration & dynamic range extension** performed manually (codes not in public repositories).

Monitoring of small showers acquisition partially implemented

- ➡ codes under augermonitoring
  - calculation of 1h-averages
  - filling of the MonitSmallShowers table (see also next slide)
- ➡ alarms under development

"Hardware" (i.e. SlowControl) monitoring in common with the other components.

- ➡ alarms missing for all AugerPrime detectors
- ➡ should add check of SPMT  $V_{mon}/I_{mon}$  ratio

# Conclusion

---

## Failures

- All failures during production and tests in labs identified. Bad units replaced by providers
- No SPMTs discarded after delivery to Malargüe

## Maintenance

- 16 out of 1477 SPMTs inspected due to suspect malfunctioning in the field. None due to the tube, solved by replacing the PMT base.
- failures in cross-calibration: <5% due to LPMTs

## Spares

- Sufficient number of spares for all parts of the SPMT units

## Software

- Cross-calibration software chain in place
- <8% failures in custom VEM evaluation
- Monitoring to be completed


## Documentation and training

- Docs and procedures available in EDMS
- Local staff trained and expert

---

# Backup

# sPMT production organization



## Ground connections for the HV CAEN A7501PB module



Fig. 5 A7501PB Front panel, LEMO HV and 4-pin Mini XLR connectors for Auger IMON




Fig. 6 A7501PB Back panel with DB15 connector

### Mini XLR


- Pin1: GND
- Pin2: n.c
- Pin3: Imon
- Pin4: n.c
- Not the entire metal enclosure of the HV module is electrically connected to GND. Only the panel housing the Mini XRL and Lemo HV connectors is wired at GND, anyway the white paint must be removed to have a good contact.

### DB15

- Pin1: Vmon
- Pin2: Vset
- Pin3: Imon
- Pin4: n.c
- Pin5: +12V
- Pin6: GND
- Pin7: GND
- Pin8: n.c.
- Pin9: n.c
- Pin10: GND
- Pin11: n.c.
- Pin12: GND
- Pin13: n.c
- Pin14: n.c.
- Pin15: n.c.



HVPS attached with the same screw used for radio (SU), possible even when radio is present




Another solution: attach it in the TPCB side, moving back the TPCB box and thus releasing a screw as the module cannot be fixed due to the height of the TPCB box which interferes with the cables outlet of the HV module

# More tests: sPMT dependence on magnetic field



[GAP2016-007]

the Earth magnetic field can affect the performances of PMTs depending on their orientation :

- deflections in phe trajectories drifting from photocathode to first dynode
- deflection of secondary e<sup>-</sup> in the dynode chain




max deviation ~2-3%  
no need for a magnetic field shielding




# sPMT - Dynamic range


Dynamic range on 20230720




Dynamic range on 20231020



Dynamic range on 20240120



Dynamic range on 20240331






# Stability of cross-calibration

$\sigma[\beta]/\beta < 4\%$

$\sigma[(S_{SPMT} - S_{LPMTs})/S_{LPMTs}]$

$\sim 10\text{-}12\%$




# Stability of cross-calibration


$\sigma[\beta]/\beta < 6\%$

$\sigma[(S_{SPMT} - S_{LPMTs})/S_{LPMTs}] \sim 13-15\%$


Inter-calibration factor  $\beta$  - Lsld 822



Daily relative dispersion of  $\beta$




Daily relative dispersion of SPMT signal w.r.t. LPMTs avg.




# Instabilities over time


Number of tanks where  $\beta \approx 0$  (failures)




Number of tanks with  $S_{\max} \in [15, 30]$  kVEM








Number of tanks with  $S_{\max} < 15$  kVEM



Number of tanks with  $S_{\max} > 30$  kVEM



# sPMT - problems



# sPMT - problems from the field



*ChicaBlu* - no  $I_{mon}$

Bad contact between the connector from PMT(  $I_{mon}$ ) and the one of the HVPS. Reconnection solved the problem




*Chiron* - unstable  $I_{mon}$

- PMT changed
- Removed PMT retested in SDEco -OK
- Divider changed even if found clean
- Insulating acrylic paint applied and sPMT container resealed


Base n.0589



Base n.1851



# sPMT - signal accuracy



SPMT signal (relative) accuracy:

- ❖ ~10% @ LPMTs saturation
- ❖ ~6% @ highest signals
- ★ Extrapolated maximum bias at highest signals:  $(2.8 \pm 2.0)\%$

Relative SPMT signal accuracy

$$\frac{\sigma_{S_{SPMT}}}{S_{SPMT}} = \sqrt{a^2 + \frac{b^2}{S_{SPMT}}}$$



- ❖ evaluated using 1 month of small showers data from 300 SPMTs:

$$a = (5.8 \pm 1.1)\%$$

$$b = (1.8 \pm 0.2) VEM^{1/2}$$

- ✓ consistent results obtained with simulations of UHE p/Fe-initiated showers in UUB twin stations

# sPMT - performances



# sPMT - codes

---

- Small showers acquisition
  - Local station DAQ: [SDEU/UUB/daq](#)
  - CDAS-DAQ: [Apps/SPMT](#)
  - example code to read small showers files: [spmt\\_example](#)
- [SPMT HV setting](#)
- Small showers acquisition monitoring (running in Lyon)
  - [calculation of 1h-averages](#)
  - [filling of the MonitSmallShowers table](#)
- [SPMT inter-calibration](#) (running in Lyon)
- SPMT inter-calibration inclusion in the SD files production (running in Lyon)
  - IoSdCalibSPMT class in [IoSdData.h](#) & [IoSdData.cc](#)
  - [SdExtraData.cc](#) & [SdExtraData.h](#)

# sPMT - monitoring

phpMyAdmin

Server: paomondb ► Database: AugerMonitor ► Tabella: MonitSmallShowers "Table filled with spmt\_data averaged over 1 hour."

Mostra Struttura SQL Cerca Inserisci Esporta Importa Operazioni Svuota Elimina

Campo	Tipo	Collation	Attributi	Null	Predefinito	Extra	Azione
Time	datetime			No			
GPSsec	int(10)		UNSIGNED	No			
LsId	smallint(5)		UNSIGNED	No			
Events	smallint(5)		UNSIGNED	No			
EventsLPMT1	smallint(5)		UNSIGNED	No			
ChargeLPMT1overChargeSPMT	float(6,2)			No			
PeakLPMT1overPeakSPMT	float(6,2)			No			
SignalLPMT1overChargeSPMT	float(6,3)			No			
AreaOverPeakLPMT1	float(6,3)			No			
EventsLPMT2	smallint(5)		UNSIGNED	No			
ChargeLPMT2overChargeSPMT	float(6,2)			No			
PeakLPMT2overPeakSPMT	float(6,2)			No			
SignalLPMT2overChargeSPMT	float(6,3)			No			
AreaOverPeakLPMT2	float(6,3)			No			
EventsLPMT3	smallint(5)		UNSIGNED	No			
ChargeLPMT3overChargeSPMT	float(6,2)			No			
PeakLPMT3overPeakSPMT	float(6,2)			No			
SignalLPMT3overChargeSPMT	float(6,3)			No			
AreaOverPeakLPMT3	float(6,3)			No			
EventsLPMTsAvg	smallint(5)		UNSIGNED	No			
AreaOverPeakSPMT	float(6,3)			No			
AreaOverPeakSSDHG	float(6,3)			No			
AreaOverPeakSSDLG	float(6,3)			No			
CustomVEMChargeLPMT1	float(6,2)			No			
CustomVEMChargeLPMT1Failures	float(6,2)			No			
MaskedStatusLPMT1	float(6,3)			No			
ThresholdLPMT1	float(6,2)			No			
OnlineVEMChargeLPMT1	float(6,2)			No			
HgLgChargeRatioLPMT1	float(6,3)			No			
CustomVEMChargeLPMT2	float(6,2)			No			
CustomVEMChargeLPMT2Failures	float(6,2)			No			
MaskedStatusLPMT2	float(6,3)			No			
ThresholdLPMT2	float(6,2)			No			
OnlineVEMChargeLPMT2	float(6,2)			No			
HgLgChargeRatioLPMT2	float(6,3)			No			
CustomVEMChargeLPMT3	float(6,2)			No			
CustomVEMChargeLPMT3Failures	float(6,2)			No			
MaskedStatusLPMT3	float(6,3)			No			
ThresholdLPMT3	float(6,2)			No			
OnlineVEMChargeLPMT3	float(6,2)			No			
HgLgChargeRatioLPMT3	float(6,3)			No			
CustomMIP	float(6,2)			No			
CustomMIPFailures	float(6,2)			No			

MonitSmallShowers table added to the AugerMonitor database

Daily and separately for each tank with a sPMT, check of :

- presence of acquired data (i.e. [number of entries in the table](#));
- number of small showers ( [Events](#) );
- And separately for each LPMT :
  - masked status ( [MaskedStatusLPMT1-2-3](#) );
  - percentage of failed VEM calibrations using the custom algorithm ( [CustomVEMCharge LPMT1-2-3Failures](#) );
  - number of events above 200 VEM ( [EventsLPMT1-2-3](#) );
  - LPMT signal over SPMT charge ratio ( [SignalLPMT1-2-3over ChargeSPMT](#) ).

43 variables - 24 entries per day per UUB tank